

**A REGULATION OF THE MUSICK MEADOWS MUTUAL WATER COMPANY #2  
(MMMWC#2)  
INSTITUTING A CROSS-CONNECTION CONTROL PROGRAM TO  
PROTECT THE PRIVATE WATER SYSTEM  
Regulation No. 2022-01**

MMMWC#2 DOES ORDAIN AS FOLLOWS:

**SECTION I – PURPOSE**

The purpose of this regulation is to protect the MMMWC#2 private water supply system from contamination due to potential and actual cross-connections. This shall be accomplished by the establishment of a cross-connection control program as required by State regulations. This regulation is adopted pursuant to Title 17, Section 7583 - 7605, inclusive, of the California Code of Regulations, entitled "Regulations Relating to Cross-Connections".

**SECTION II – RESPONSIBILITY**

The MMMWC#2 Board of Directors shall be responsible for implementing and enforcing the cross-connection control program. An appropriate backflow prevention assembly shall be installed by MMMWC#2, at the expense of the water user at each user connection where required to prevent backflow from the water user's premises to the domestic water system.

**SECTION III - CROSS-CONNECTION PROTECTION REQUIREMENTS**

The type of protection that shall be provided to prevent backflow into the private water supply system shall be commensurate with the degree of hazard, actual or potential, that exists on the water user's premises. Unprotected cross-connections with the water supply are prohibited.

The type of backflow prevention assembly that may be required (listed in decreasing level of protection) includes: Air-gap separation (AG), Reduced Pressure Principle Backflow Prevention Assembly (RP), and a Double Check Valve Assembly (DC). The minimum types of backflow protection required to protect the approved water supply at the user's water connection to premises with varying degrees of hazard are listed in Table 1 of Section 7604, Title 17 of the California Regulations related to drinking water. Situations which are not covered in Table 1 shall be evaluated on a case-by-case basis. The appropriate backflow protection shall be determined by MMMWC#2 or health agency.

**SECTION IV - BACKFLOW PREVENTION ASSEMBLIES**

Location of the backflow assemblies shall be as close as practical to the user's connection. MMMWC#2 shall have the final authority in determining the required location of a backflow prevention assembly.

Testing of backflow assemblies shall be conducted only by certified testers and testing will be the responsibility of MMMWC#2. Backflow prevention assemblies will be tested at least annually and immediately after installation, relocation or repair. More frequent testing may be required if deemed necessary by MMMWC#2 or the State Water Board. All costs associated with inspecting, testing, repairing, and maintenance of backflow prevention assemblies shall be borne by the water user. A water user may not remove, relocate or modify a backflow prevention assembly.

a lien placed upon the property consistent with ARTICLE XVII, Assessments, Collections and Liens of the MMMWC#2 Bylaws.

**SECTION VIII - EFFECTIVE DATE**

This Regulation shall take effect immediately upon adoption.

**SECTION IX – VERIFICATION**

This Regulation was passed and adopted by the MMMWC#2 Board on February 9, 2018, and amended on October 22, 2022. I certify that the foregoing is a full, true, and correct copy of Resolution –2022-01,

A handwritten signature in black ink, appearing to read 'Mike Leonardo', is written over a solid horizontal line.

Mike Leonardo  
MMMWC#2 Board President

Amended October 22, 2022